



Department of Transportation

Aberdeen Region Office

West Highway 12

PO Box 1767

Aberdeen, South Dakota 57402-1767 605/626-2244

FAX: 605/626-7875

August 13, 2008

ADDENDUM NO. 2

Re: **August 15, 2008 Letting**
029 S-172, PCN i18z, Roberts County
Glacial Lakes (Victor) Rest Area Sandblast and Paint 2 Picnic Shelter Canopies

TO WHOM IT MAY CONCERN:

The following addendum to the plans shall be inserted and made part of your proposal for the above referenced project.

The letting date on this project will be changed from August 15, 2008 to 1:30 PM Friday, August 22, 2008.

Included with this Addendum are the results of the lead test of the existing paint on the shelter canopies. The Contractor should review these results and plan his work accordingly.

Plan Sheets:

Sheet 2 of 6: Pen and ink delete the following statement in the 2nd column just above the heading "Basis of Measurement and Payment": "however the DOT would like to have the work started and completed between 8/18/08 and 8/28/08".

When sending in your sealed bid please state on the front of the envelope that Addendum No. 2 was received.

Sincerely,

DEPARTMENT OF TRANSPORTATION

Jeff Senst, P.E.
Region Engineer

cc: Plan Holders

File



2381 South Plaza Drive P.O. Box 3388 Rapid City, SD 57709
(605) 348-0111 -- www.thechemistrylab.com

Sample Site: Picnic Shelter Canopy
Project Name: Glacial Lakes Rest Area
Project Number: 0295-172 PCNi18z
Sampled: 07/28/08 at 11:30 AM
by Jerry Maier
Sample Matrix: Solid

JERRY MAIER
SD DOT ABERDEEN REGION OFFICE
PO BOX 1767
ABERDEEN, SD 57402-1767

Lab ID#: 20080731705
Received: 07/31/08 at 04:00 PM
by Dean Aurand
Account: W1449
SD DOT Aberdeen Region Office

Parameter	Result	Units	DF	MDL	PQL	Method	Analyst/Date
-----------	--------	-------	----	-----	-----	--------	--------------

Metals - Total

Lead (Pb)	7.72	mg/kg	2000	0.037	0.200	EPA 200.8	EJF 08/04/08
-----------	------	-------	------	-------	-------	-----------	--------------

Approved By: _____

Approved On: 8/12/2008 9:33:03 AM